

NIC

GOVERNMENT OF PUDUCHERRY  
ELECTRICITY DEPARTMENT

LCE No. 07 /EDK/EE /AEE/C&B/F.21/2017-2018 /179

Karaikal  
Dt: 5 .03. 2018

**ENQUIRY**

**Sub:** - Electricity Department – Enquiry for the Supply, Erection, Testing and Commissioning of 3 nos. of 2.0 tonne split type Air conditioner units and 1 no. of 1.5 tonne split type Air conditioner units ~~at~~ various location of Electricity Department, Karaikal. – **Quotation called for – Reg.**

\*\*\*\*\*

Sealed Quotation are hereby invited by the Executive Engineer, Electricity Department, Karaikal, on behalf of the President of India from contractors experienced in similar field of work for "Supply, Erection, Testing and Commissioning of 3 no. of 2.0 tonne split type Air conditioner units and 1 no. of 1.5 tonne split type Air conditioner unit to the below mentioned locations at Electricity Department, Karaikal. The offers should reach this office on or before **03.00 P.M of 5.03. 2018** and the same will opened on **04.00 P.M** on the same day in the chamber of the Executive Engineer, Electricity Department, Karaikal. Those tenderers who are willing may be present at that time. If the opening date happens to be a holiday, the next working day will be treated as the opening day.

Sl. No.	Description of Work	Quantity	Rate
1.	Supply, Erection, Testing and Commissioning of 2.0 tonne split type Air conditioner units of <b>Make:</b> Hitachi/Blue star /Voltas/Carrier or equivalent with 3 star rating certified by BEE Nominal cooling capacity K.cal/Hr 6000(2.0 tonne), maximum power consumption 2200 watts, minimum cooling capacity K.cal/Hr 6000(2.0 tonne). Minimum room discharge Air flow cum/Hr 800, Energy efficient. The Air conditioner unit shall be suitable for operating on 230 Volt+10%, 50 Hz, single phase AC supply, capable of performing dehumidifying, cooling filtering ventilation special feature like sensing the human body movement, Air conditioner unit fitted with cooled compressor operating on refrigerant R-22 with suitable rated capacitor start electric motor. Air conditioner unit shall confirming to IS 10617 (part-I) 1083 with (AMDT- 1 and 2) and suitable for wall mounting wireless remote control shall be provided with ON/OFF timer, selecting speed etc., Location at (i) Computer section, Main office (2Nos) (ii) 110/11KV P.T.Vasal sub-station.(1No)	<b>3 Nos</b>	
2.	Supply, Erection, Testing and Commissioning of 1.5 tonne split type Air conditioner units of <b>Make:</b> Hitachi/Blue star /Voltas/Carrier or equivalent with 3 star rating certified by BEE Nominal cooling capacity K.cal/Hr 4500(1.5 tonne), maximum power consumption 1750 watts, minimum cooling capacity K.cal/Hr 4500(1.5 tonne). Minimum room discharge Air flow cum/Hr 800, Energy efficient. The Air conditioner unit shall be suitable for operating on 230 Volt+10%, 50 Hz, single phase AC supply, capable of performing dehumidifying, cooling filtering ventilation special feature like sensing the human body movement, Air conditioner unit fitted with cooled compressor operating on refrigerant R-22 with suitable rated capacitor start electric motor. Air conditioner unit shall confirming to IS 10617 (part-I) 1083 with (AMDT- 1 and 2) and suitable for wall mounting wireless remote control shall be provided with ON/OFF timer, selecting speed etc. Location at 110/11KV Sorakudy sub-station	<b>1 No</b>	

GOVT. OF INDIA  
NIC DISTRICT UNIT,  
KARAIKAL,  
RECEIVED DATE: 07-03-2018

3.	Supply, Erection, Testing and commissioning of 5KVA, 230V, 50Hz voltage stabilizer (Make: Everest/premier/V-Guard/reputed make) (wall mounting type) working range shall be 170V to 270 V to give out put voltage of range 190V to 240V with bucking/boosting and shall have built in time delay of power supply and dual relay for increasing/decreasing voltage, auto restart facility when the voltage decreasing/increasing after high/low off action.	3 Nos
4.	Supply, Erection, Testing and commissioning of 4KVA, 230V, 50Hz voltage stabilizer (Make: Everest/premier/V-Guard/reputed make) (wall mounting type) working range shall be 170V to 270 V to give out put voltage of range 190V to 240V with bucking/boosting and shall have built in time delay of power supply and dual relay for increasing/decreasing voltage, auto restart facility when the voltage decreasing/increasing after high/low off action.	1 No
5.	Condensing unit stand	4 Nos
6.	Extra copper pipe	Per/meter
7.	Buy Back of old Air conditioner (split type 2.0 tonne)	3 Nos
8.	Buy Back of old Air conditioner (window type type 1.5 tonne)	1 No

**Terms and Conditions:**

1. The rate shall be inclusive of all taxes (GST/IT).
2. The GST and IT shall be deducted at the time of bill settlement as per norms.
3. The work shall be completed within 15 days from date of receipt of work order.
4. The warranty card shall be given.
5. The payment will be made within 30 days on receipt of the bill.
6. The work shall be carried out to the satisfaction of the department.
7. Warranty for the machine and compressor shall be clearly mentioned.
8. Copper pipe supplied with Air conditioner may clearly specified if extra copper is to be added, rate may be quoted separately for per meter basis.

Yours faithfully,

*S. R. S.*  
Executive Engineer/Karaikal  
Electricity Department  
Karaikal  
12/15

To

1. M/s. Nachiya stores, No.77, Thirunallar road, Karaikal.
2. M/s. Sona Aircons, No.4, Three well plaz street, Karaikal.
3. M/s. Subayoha Agencies, No194/3, Bharathiar road, Karaikal.
4. M/s. Weather control appliances, No.48, Mamathambi Maraicar street,Karaikal.
5. M/s. Standard Refrigeration, No, 54, Maideen palli street,Karaikal.
6. M/s. National Refrigeration services, No.148, Kamaraj salai,Karaikal.
7. M/s. Samsung Plaza,Pearl Aircons, 279,Bhararathiar road, (Near LIC), Karaikal.
8. M/s. Lakshmi Enterprises, No.207, Bharathiar road, Karaikal.
9. M/s. AMA Agencies, No.198, Thirunallar road, Karaikal.
10. M/s. V.M.Traders, LG SHOPPE, No.193, Bharathiar road, karaikal
11. M/s. Superior Refrigeration & Rewinding works, 57/2. Mamathambi maraicar st, Karaikal.

The notice board, Electricity Department, Karaikal

✓ The NIC.website, Karaikal.

Copy to:

The Assistant Engineer/computer, Electricity Department, Puducherry.  
The Junior Engineer/Buildings, Electricity Department, Karaikal.

*The National Informatic officer  
N.I. C; KARAICAL - with a request to put up in the Karaikal  
website*